

Annexure C

PROFORMA FOR SAFE DRINKING WATER AND SANITARY CONDITION CERTIFICATE

No. 666

Dated: 25/08/2025

It is certified that an inspection team headed by Vishwambhar Kumar Mandal, Asst Eng.

(Name of Officers with designation) from Public Health Sub-division, PHED, Samastipur

inspected the Delhi Public School Tajpur, Samastipur

(Name & Address of the school) on 25/08/25 (date of inspection) and on the basis of

Water Test Report (Attached) bearing no. 665 dated 25/08/25

c: Public Health Sub-division (PHED Lab) certified that the

Delhi Public School Tajpur (Name of school) has safe drinking water

facilities for the students and members of staff of the institution. School is also maintains the

hygienic sanitation condition in the school building & the campus as per norms prescribed by the

Central/ State/ U.T. Govt.

This certificate is valid till 24.08.2026 (1 year)

Signature with Seal:

Name

Designation

Name & Address of the Office / Department



25/08/25

Vishwambhar Kumar Mandal

Asst. Engg. PHED Division

Sub Divisional Officer
P.H. Sub. Division, Samastipur

To

Principal

Delhi Public School Tajpur

(Name & Address of the Institution)

Kasbeahar, Tajpur, Samastipur

Note: The certificate is to be issued by authorized officer / PHED Lab / local bodies

Government of Bihar
Public Health Engineering Department

DISTRICT :- SAMASTIPUR			DIVISION :- SAMASTIPUR							MONTH:-AUGUST 2025					
S.N.	BLOCK	PANCHAYAT	LOCATION OF SOURCE	PARAMETERS											REMARKS
				pH	TURB	EC	TDS	TH	Ca	Cl	Mg	Alka.	Fe	T.CO.U	
1	TAJPUR	KASBA AAHAR	DELHI PUBLIC SCHOOL	7.2	1	185	120	65	45	20	28	83	0.2	-Ve	
Acceptable Limit as per BIS 10500/2012				6.5-8.5	1 NTU	-	500 mg/l	200 mg/l	75 mg/l	250m g/l	30 mg/l	200 mg/l	1.0mg/l		
Permissible Limit* in absence of alternate source as per BIS 10500/2012				NR	5 NTU	-	2000 mg/l	600 mg/l	200 mg/l	1000 mg/l	100 mg/l	600 mg/l	NR		

Soni
25/08/25
Chemist / Lab Assistant
P.H. Division Samastipur

