


PERFORMA FOR SAFE DRINKING WATER AND SANITARY CONDITION CERTIFICATE

No.:- 249

Date:- 27/06/2023

It is certified that an inspection team headed by **Akash Sahani, Assistant Engineer, P.H.E.D, Samastipur** (Name of Officers with Designation) From **Public Health Subdivision, Samastipur** (Name of Department/Office) inspected the **DELHI PUBLIC SCHOOL, TAJPUR, BORING ROAD, TAJPUR, SAMASTIPUR** Address of the school) on **20.06.2023** and found that the **DELHI PUBLIC SCHOOL** (Name of School) has safe drinking water for the students and members of staff of the institution and is maintaining the hygienic sanitation condition in the school building & the campus as per norms prescribed by the Central/State/ U.T Govt.

The above valid for a period of :- **One year only**

Signature with Seal.....
22/06/23

Name :- **Akash Sahani**

Designation :- **Sub Divisional Officer**
Sub. Division, Samastipur

TO,

PRINCIPAL
DELHI PUBLIC SCHOOL TAJPUR
BORING ROAD, TAJPUR, SAMASTIPUR,
Bihar-848130.

(Name & Address of the Institution)


DISTRICT :- SAMASTIPUR

Government of Bihar
Public Health Engineering Department
DIVISION :- SAMASTIPUR

MONTH:- JUNE 2023

S.N.	BLOCK	PANCHAYAT	WARD	LOCATION OF SOURCE	PARAMETERS													REMARKS
					pH	TURB.	EC	TDS	TH	Ca	Mg	Cl	Alka.	NO3				
1	TAJPUR	TAJPUR	19	DELHI PUBLIC SCHOOL TAJPUR RAW WATER	7.3	2	504	328	NT	24	NT	30	176	BDL				
2	TAJPUR	TAJPUR	19	DELHI PUBLIC SCHOOL TAJPUR R O WATER	7.2	1	64	42	NT	8	NT	10	30	BDL				
Acceptable Limit as per BIS 10500/2012					6.5-8.5	1 NTU	-	500 mg/l	200 mg/l	75mg/l	30mg/l	250mg/l	200 mg/l	45mg/l				
Permissible Limit* In absence of alternate source as per BIS 10500/2012					NR	5 NTU	-	2000 mg/l	600 mg/l	200 mg/l	100 mg/l	1000 mg/l	600 mg/l	NR				


11.06.23
CHEMIST


22/06/23
EXECUTIVE ENGINEER
P.H.E. Division
Samastipur

Executive Engineer
Public Health Division
Samastipur